

## Article 28 - NFPA 385-2000: Standard For Tank Vehicles For Flammable and Combustible Liquids

(The following Indiana Amendments are reprinted here from the Indiana government web site for your convenience. We have not edited or reformatted these pages, nor have we reviewed the for accuracy. We assume them to be identical to the official amendments as originally printed in the Indiana Register. We make no stated or implied claim as to their accuracy.)

---

675 IAC 28-1-34 NFPA 385; standard for tank vehicles for flammable and combustible liquids

Authority: IC 22-13-2-2; IC 22-13-2-13

Affected: IC 10-19-2; IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 34. (a) That certain document, being titled NFPA 385-Standard for Tank Vehicles for Flammable and Combustible Liquids, 2000 Edition, published by the National Fire Protection Association (NFPA), 1 Batterymarch Park, Quincy, Massachusetts 02269-9101, be and the same is hereby adopted by reference except as revised hereafter.

(b) The following documents referenced in NFPA 385 are not adopted, are not enforceable, and are for information purposes only:

- (1) NFPA 30.
- (2) ANSI Z 535.1.
- (3) ASTM B 209.
- (4) ASTM D 5.
- (5) ASTM D 323.
- (6) Title 49, Code of Federal Regulations.

(c) The following documents referenced in NFPA 385 are adopted and are enforceable:

- (1) NFPA 10, as adopted in section 2 of this rule.
- (2) NFPA 58, as adopted in 675 IAC22-2.2-14.
- (3) NFPA 70, as adopted in 675 IAC 17.
- (4) NFPA 407, as adopted [*sic., in*] section 36 of this rule.
- (5) ASME Boiler and Pressure Vessel Code, as adopted at 680 IAC 2-1-1.

(d) Amend Section 1-2 as follows:

(1) Amend the following definitions to read as follows:

APPROVED means acceptance by the authority having jurisdiction by one (1) of the following methods:

- (1) Investigation or tests conducted by nationally recognized authorities; or
- (2) Investigation or tests conducted by nationally recognized technical or scientific organizations; or
- (3) Nationally accepted principles.

The investigation, tests, or principles shall establish that the method, material, equipment, design, or type of construction is safe for its intended purpose.

COMBUSTIBLE LIQUID means a liquid having a closed cup flash point as specified by the Fire Code (675 IAC 22-2.3).

FLAMMABLE LIQUID means a liquid having a closed cup flash point as specified by the Fire Code (675 IAC 22-2.3).

LABELED means equipment or materials to which has been attached a label, symbol, or other identifying mark of an organization engaged in product evaluation, that maintains periodic inspection of production of labeled equipment or materials, and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

LIQUID means a material having a melting point as specified by section 2702 of the Fire Code (675 IAC 22-2.3).

LISTED means equipment or materials included in a list published by an organization engaged in product evaluation, that maintains periodic inspection of production of listed equipment or

materials, and whose listing states either that the equipment or material meets appropriate standards or has been tested and found suitable for use in a specified manner.

(2) Add the following definitions:

AUTHORITY HAVING JURISDICTION means the Division of Fire and Building Safety or officer of a local unit of government empowered by law to administer and enforce the rules of the commission.

DIVISION OF FIRE AND BUILDING SAFETY means the Division of Fire and Building Safety of the Indiana Department of Homeland Security created pursuant to IC 10-19-2.

INDIANA FIRE CODE means the rules adopted at 675 IAC 22 in effect in Indiana at the time of inspection by the inspection authority or, with respect to construction required to be filed under 675 IAC 12-6, 675 IAC 22 in effect at the time of construction, remodeling, alteration, addition, or repair of the structure.

NFPA 70 means the Indiana Electrical Code (675 IAC 17).

(e) Delete Section 4-1.1 without substitution.

(f) Chapter 7 and the appendices are not adopted as part of this code and are intended for use as a guide, and the standards referenced therein are not enforceable as part of this code. (*Fire Prevention and Building Safety Commission; 675 IAC 28-1-34; filed Aug 23, 2006, 4:03 p.m.: 20060906-IR-675050104FRA*)